

400 N Lake Ave – Crandon, WI 54520 I 2420 N Grandview Blvd – Waukesha, WI 53188 P: 800-278-1254 F: 715-478-3060 E: <u>clientservices@nlslab.com</u>

Copper and/or Lead Sample Collection

- 1. Avoid any "New" Plumbing
- 2. A cold water tap commonly used for drinking water should be selected for sampling. Do not remove aerator. The tap should not have any filtration device attached.
- 3. First Draw Collect water that has not been used for at least 6 hours prior to collection. Do not collect water from taps where water has remained motionless for significantly longer than 6 hours (i.e. vacant properties or homes where residents are not at home for up to 2 weeks or longer). Commonly used to uncover potential problems with metals leaching into the drinking water from pipes and fixtures in the home.
- 4. The bottle MUST be filled to at least the 1000mL line or the **sample will be rejected**.
- 5. Copper and/or Lead samples have a 14-day hold time from collection to receipt at the lab. Please return samples to us within 12 days of collection, so as not to exceed the hold time.